

NOTES:

- MUST BE MIN. 36" AWAY FROM ANY ELECTRICAL PANEL.
- VALVE REQUIRED DOWNSTREAM OF BACKFLOW ASSEMBLY.
- VERTICAL INSTALLATION SHALL BE DESIGNED AND SUBMITTED TO CFPUA EMD FOR APPROVAL.
- LOCATE AS NEAR TO RIGHT-OF-WAY AS POSSIBLE.
- MUST COMPLETE CFPUA'S BACKFLOW INSTALLATION FORM. CONTACT COMMUNITY COMPLIANCE AT 910-332-6558 OR VISIT WWW.CFPUA.ORG/COMMUNITYCOMPLIANCE AND COMPLETE THE ONLINE FORM.
- ONLY IN-LINE TESTABLE ASSEMBLIES APPROVED BY THE USC FOUNDATION FOR CROSS CONNECTION CONTROL OR ASSE SHALL BE ACCEPTED.

OUTDOOR HORIZONTAL INSTALLATION

