


120/208V, 3PH, 4W
60 HERTZ

NOTE:
THIS DETAIL DEPICTS TYPICAL ACROSS THE LINE MOTOR STARTERS. SEE PUMP CONTROL PANEL SPECIFICATIONS WHERE RVAT OR SOLID STATE SOFT STARTERS MAY BE REQUIRED.



SEE CONTINUATION OF SCHEMATIC ON DETAIL PCP-3

DETAIL: PUMP CONTROL PANEL SCHEMATIC 120/208V 3 PH SERVICE	
SCALE: NOT TO SCALE	CFPUA DETAIL DATE: 01/01/19
CFPUA REV. No: 1	

CAPE FEAR PUBLIC UTILITY AUTHORITY
 235 GOVERNMENT CENTER DRIVE
 WILMINGTON, NC 28403
 OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO: PCP-2B
SHEET NO: -