




PUMP 1 RUN STATUS




PUMP 2 RUN STATUS




MOTOR 1 OVERTEMP ALARM



MOTOR 2 OVERTEMP ALARM




MOTOR 1 OVERLOAD ALARM




MOTOR 2 OVERLOAD ALARM




PUMP 1 HOA NOT IN "AUTO"




PUMP 2 HOA NOT IN "AUTO"



HIGH LEVEL



HIGH/HIGH LEVEL



POWER PROBLEM



DETAIL:

**PUMP CONTROL PANEL SCHEMATIC**

SCALE: NOT TO SCALE

CFPUA DETAIL DATE:

CFPUA REV. NO: 2

01/01/20



CAPE FEAR PUBLIC UTILITY AUTHORITY  
235 GOVERNMENT CENTER DRIVE  
WILMINGTON, NC 28403  
OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO:

**PCP-8**

SHEET NO:

-