



NOTES:

1. PROVIDE EITHER A CONCRETE SLAB (DESIGNED BY ENGINEER) OR A STONE/GRAVEL BASE LAYER TO BE DETERMINED BY CFPUA.
2. 4" THICK FLOOR (PROVIDE WITH STONE/GRAVEL BASE LAYER).
3. 4" THICK ROOF CAP, SLOPED TO THE BACK.
4. 3" THICK WALLS.
5. FORM FINISH INTERIOR CONCRETE WALLS, PAINT 1 PRIMER COAT & 2 FINISH COATS WHITE.

DETAIL:

PRECAST BUILDING PLAN

SCALE: NOT TO SCALE

CFPUA DETAIL DATE:

CFPUA REV. No: 1

01/01/19



CAPE FEAR PUBLIC UTILITY AUTHORITY
 235 GOVERNMENT CENTER DRIVE
 WILMINGTON, NC 28403
 OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO:

PS-B1

SHEET NO:

-