



BRACKET DETAILS AND SECTIONS
NOT TO SCALE

NOTES:

1. UNLESS OTHERWISE SPECIFIED, ALL METAL WET WELL COMPONENTS, HARDWARE, AND FASTENERS, SHALL BE CAST IRON, DUCTILE IRON OR 316 STAINLESS STEEL OR BETTER.
2. UNLESS OTHERWISE SPECIFIED, ALL CONCRETE FASTENERS TO BE 316 STAINLESS STEEL WEDGE ANCHORS (TYP).
3. ONE PIECE SCHEDULE 40, 316 STAINLESS STEEL GUIDE RAILS. DIAMETER PER MANUFACTURERS RECOMMENDATIONS. TWO PIECE RAILS WITH INTERMEDIATE (MID 1/3) SUPPORT, FOR LENGTHS GREATER THAN 18 FEET. UPPER GUIDE RAIL BRACKET SHALL ALSO BE STAINLESS STEEL.

DETAIL:	
PUMP DISCHARGE SUPPORT	
SCALE: NOT TO SCALE	CFPUA DETAIL DATE:
CFPUA REV. No: 1	01/01/19

CAPE FEAR PUBLIC UTILITY AUTHORITY
235 GOVERNMENT CENTER DRIVE
WILMINGTON, NC 28403
OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO:
PS-C3A
SHEET NO:
-