



ELECTRICAL EQUIPMENT ENCLOSURE: SHELTERWORKS, INC. FREEDOM SERIES 6'x8'x8' SHOWN. CONFIRM FINAL ENCLOSURE DIMENSIONS REQUIRED WITH EQUIPMENT TO BE HOUSED. ENSURE CODE REQUIRED WORK CLEARANCES IN FRONT OF EQUIPMENT WITH DOORS OPEN. VERIFY ENCLOSURE DIMENSIONS REQUIRED FROM EQUIPMENT SUBMITTAL DOCUMENTS AND PROVIDE SUITABLY SIZED ENCLOSURE. OVERALL LENGTH OF MOUNTING FRAME SHALL CORRESPOND TO ENCLOSURE DIMENSIONS.

DETAIL:	
EQUIPMENT PAD PLAN FRP EQUIPMENT ENCLOSURE	
SCALE: NOT TO SCALE	CFPUA DETAIL DATE:
CFPUA REV. No: 1	01/01/19

CAPE FEAR PUBLIC UTILITY AUTHORITY
 235 GOVERNMENT CENTER DRIVE
 WILMINGTON, NC 28403
 OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO: PS-E2
SHEET NO: -