



**NOTES:**

1. TRACER WIRE SHALL PENETRATE VALVE BOX THROUGH DRILLED HOLE APPROX. 6" BELOW GRADE WITH MINIMUM 2- FEET EXTRA LENGTH COILED IN THE VALVE BOX. SEE WS-6.

DETAIL:	
<b>VALVE DETAIL</b>	
SCALE: NOT TO SCALE	CFPUA DETAIL DATE:
CFPUA REV. No: 1	01/01/19



**CAPE FEAR PUBLIC UTILITY AUTHORITY**  
 235 GOVERNMENT CENTER DRIVE  
 WILMINGTON, NC 28403  
 OFFICE: (910)332-6560

Stewardship. Sustainability. Service.

DETAIL NO:
<b>WS-5</b>
SHEET NO:
-