
NOTES:

- NO JOINT SHALL BE INSTALLED BETWEEN THE MAIN SERVICE TAP AND THE METER STOP. ALL SERVICES SHALL BE INSTALLED PERPENDICULAR TO MAIN.
- SERVICE SADDLES ON PVC MAINS SHALL BE WIDE BAND BRASS BODY.
- METER BOXES SUBJECT TO TRAFFIC LOADS SHALL CONFORM TO ASTM A48, CLASS 30B AND AASHTO H20 LOAD RATING STANDARDS.
- WATER SERVICE LINE SHALL TERMINATE 18" WITHIN RIGHT-OF-WAY LINE.
- WATER METER BOXES ARE TO BE A MINIMUM OF 5 FEET FROM THE PROPERTY CORNER.
- SERVICE PIPING AND METER SETTER TO BE CENTERED IN THE METER BOX.
- TRACING WIRE SHALL BE INSTALLED WITH ADHESIVE TAPE AT 12' INTERVALS AND EXTEND A MINIMUM OF 2' OUTSIDE OF METER BOX PER CFPUA DETAIL WS-6.
- PLASTIC PIPE STIFFENERS SHALL BE USED.





CAPE FEAR PUBLIC UTILITY AUTHORITY 235 GOVERNMENT CENTER DRIVE WILMINGTON, NC 28403 OFFICE: (910)332-6560

DETAIL NO: W-1

SHEET NO:

S.\TeatmentEngCM\Engineer\2003_Project Management\2017 Projects\-Standards Update 314817.045\CFPUA Dwg Details\CAD\W-1 Single Water Service Connection - Short-Side.dwg, 12/11/2024 12:12:54 PIM, justin.hanes