



NOTES:

1. ALL WATER SERVICES SHALL BE INSTALLED PERPENDICULAR TO MAIN AND TERMINATE 18" INSIDE THE RIGHT OF WAY.
2. WATER SERVICE SADDLES ON PVC MAINS SHALL BE WIDE BAND BRASS BODY.
3. METER BOXES SUBJECT TO TRAFFIC SHALL CONFORM TO ASTM A48, CLASS 30B AND AASHTO H20 LOAD RATING STANDARDS.
4. 3" CLEAN FILL REQUIRED ALL AROUND 1" POLY SERVICE LINE.
5. JOINT RESTRAINT SYSTEMS SHALL BE WEDGE ACTION STYLE FOR DI OR C-900 PVC PIPE.
6. METER BOXES SHALL BE LOCATED MINIMUM 5- FEET FROM THE PROPERTY CORNER.
7. ASSEMBLY TO BE CENTERED IN THE METER BOX.

DETAIL: DOUBLE WATER SERVICE - DOMESTIC AND IRRIGATION SPLIT		 CAPE FEAR PUBLIC UTILITY AUTHORITY 235 GOVERNMENT CENTER DRIVE WILMINGTON, NC 28403 OFFICE: (910)332-6560 Stewardship. Sustainability. Service.	DETAIL NO: W-5
SCALE: NOT TO SCALE	CFPUA DETAIL DATE: 01/01/19		SHEET NO: -
CFPUA REV. No: 1			