



Addendum 1
Wild Dunes Ground Storage Tank Rehabilitation
October 29, 2025

BID DUE DATE: Tuesday, November 25, 2025 at 11:00AM (as originally advertised)

TO ALL BIDDERS:

Below are changes and or clarifications to the bid documents for this project. This Addendum forms a part of the Contract Documents and modifies the original bidding documents as noted below. Acknowledge receipt of this Addendum as required in the bid documents. Failure to do so may subject Bidder to disqualification.

BID FORM REVISIONS:

None at this time.

TECHNICAL SPECIFICATION REVISION:

1. In Section 01 11 00 Summary of Work; 1.3 Contract Description; A.; remove item 4. and replace with the following:
 4. Interior wet: Minor concrete repairs and clean interior surface.

DRAWING REVISIONS:

None at this time.

CLARIFICATIONS:

1. The interior piping shall be blasted and coated. The interior wet concrete surface shall have minor concrete repairs and be cleaned but shall not be coated.

QUESTIONS RECEIVED:

None at this time.

ACKNOWLEDGEMENT BY BIDDER. Bidder shall acknowledge receipt of this Addendum No. 1 in the space provided in the Bid Form.

All other terms & conditions remain unchanged.

Teresa McPherson
Cape Fear Public Utility Authority
Bid Manager
End of Addendum 1

John Kupinski
Cape Fear Public Utility Authority
Project Manager